

## GRID SYSTEM OPERATION SUMMARY (PENINSULAR MALAYSIA)

	FORECAST	ACTUAL	VARIANCE	
Maximum Demand for 6 August 2012	13,889 MW	13,548 MW	-2.46%	
Energy Demand for 6 August 2012	296.89 GWh	291.29 GWh	-1.89%	
Highest Maximum Demand (20 June 2012)	15,685 MW	15,826 MW	0.90%	*New MD
Highest Daily Energy Demand (20 June 2012)	326.75 GWh	328.72 GWh	0.60%	*New Energy

Prepared by:

Electricity Market Operations


Electricity Supply & Market Regulations Dept.

Energy Commission Malaysia

07-Aug-12


**Daily Owners' Mix for 6 August 2012**

<b>TNB</b>	59,655 MWh
<b>IPP</b>	230,273 MWh
<b>Co-Gen</b>	1,970 MWh
<b>Interconnection*</b>	606 MWh



**Daily Generation Mix for 6 August 2012**

<b>ST-Coal</b>	140,408 MWh
<b>ST-Oil</b>	- MWh
<b>ST-Gas</b>	93 MWh
<b>Gas</b>	139,553 MWh
<b>Hydro</b>	9,874 MWh
<b>Distillate</b>	- MWh
<b>Co-Gen</b>	1,970 MWh
<b>SPORE*</b>	90 MWh
<b>EGAT*</b>	516 MWh



\*Negative = energy is imported from Singapore and Thailand  
 Positive = energy is exported to Singapore and Thailand