

GRID SYSTEM OPERATION SUMMARY (PENINSULAR MALAYSIA)

	FORECAST	ACTUAL	VARIANCE	
Maximum Demand for 7 December 2012	14,747 MW	14,884 MW	0.93%	
Energy Demand for 7 December 2012	307.75 GWh	309.03 GWh	0.42%	
Highest Maximum Demand (20 June 2012)	15,685 MW	15,826 MW	0.90%	*New MD
Highest Daily Energy Demand (20 June 2012)	326.75 GWh	328.72 GWh	0.60%	*New Energy

Prepared by:

Electricity Market Operations


Electricity Supply & Market Regulations Dept.

Energy Commission Malaysia

08-Dec-12


Daily Owners' Mix for 7 December 2012

TNB	69,573 MWh
IPP	237,854 MWh
Co-Gen	2,117 MWh
Interconnection*	512 MWh



Daily Generation Mix for 7 December 2012

ST-Coal	146,134 MWh
ST-Oil	47 MWh
ST-Gas	- MWh
Gas	152,623 MWh
Hydro	8,623 MWh
Distillate	- MWh
Co-Gen	2,117 MWh
SPORE*	(219) MWh
EGAT*	731 MWh



*Negative = energy is imported from Singapore and Thailand
 Positive = energy is exported to Singapore and Thailand