

## GRID SYSTEM OPERATION SUMMARY (PENINSULAR MALAYSIA)

	FORECAST	ACTUAL	VARIANCE	
Maximum Demand for 21 December 2012	14,503 MW	14,313 MW	-1.31%	
Energy Demand for 21 December 2012	303.51 GWh	300.67 GWh	-0.94%	
Highest Maximum Demand (20 June 2012)	15,685 MW	15,826 MW	0.90%	*New MD
Highest Daily Energy Demand (20 June 2012)	326.75 GWh	328.72 GWh	0.60%	*New Energy

Prepared by:

Electricity Market Operations


Electricity Supply & Market Regulations Dept.

Energy Commission Malaysia

22-Dec-12


**Daily Owners' Mix for 21 December 2012**

TNB	59,856 MWh
IPP	240,118 MWh
Co-Gen	1,545 MWh
Interconnection*	846 MWh



**Daily Generation Mix for 21 December 2012**

ST-Coal	156,750 MWh
ST-Oil	- MWh
ST-Gas	- MWh
Gas	136,372 MWh
Hydro	6,852 MWh
Distillate	- MWh
Co-Gen	1,545 MWh
SPORE*	119 MWh
EGAT*	727 MWh



\*Negative = energy is imported from Singapore and Thailand  
 Positive = energy is exported to Singapore and Thailand