


GRID SYSTEM OPERATION SUMMARY (PENINSULAR MALAYSIA)

	FORECAST	ACTUAL	VARIANCE	
Maximum Demand for 16 May 2013	16,000 MW	16,099 MW	0.62%	
Energy Demand for 16 May 2013	333.95 GWh	335.92 GWh	0.59%	
Highest Maximum Demand (13 May 2013)	16,298 MW	16,562 MW	1.62%	*New MD
Highest Daily Energy Demand (14 May 2013)	345.42 GWh	344.42 GWh	-0.29%	*New Energy

Prepared by:
Electricity Market Operations
Electricity Supply & Market Regulations Dept.
Energy Commission Malaysia
17-May-13


Daily Owners' Mix for 16 May 2013

TNB	80,881 MWh
IPP	248,470 MWh
Co-Gen	1,154 MWh
Interconnection*	(5,417) MWh



Daily Generation Mix for 16 May 2013

ST-Coal	127,114 MWh
ST-Oil	7,835 MWh
ST-Gas	- MWh
Gas	140,114 MWh
Hydro	16,452 MWh
Distillate	37,836 MWh
Co-Gen	1,154 MWh
SPORE*	(4,717) MWh
EGAT*	(700) MWh



*Negative = energy is imported from Singapore and Thailand
 Positive = energy is exported to Singapore and Thailand