

PART III

GAS INSTALLATION

13. Classification of gas installation.

All gas installations shall be classified in accordance with the classes as specified in Table 1 of the Second Schedule.

14. Installation to be carried out in accordance with Regulations.

Every work on a gas installation shall be carried out in accordance with these Regulations and any condition as may be determined by the Director General.

15. Approval to install.

(1) Before commencing work on a new installation or gas extension, a person shall apply to the Director General for an approval to install and shall attach the drawings of the system properly engineered to a suitable scale or in isometric projection showing all the details of the gas installation.

(2) The drawings referred to in subregulation (1) shall be endorsed by a Gas Engineer, Gas Engineering Supervisor, Class I Gas Fitter or Class II Gas Fitter, as the case may be.

(3) The Director General may approve the application if he is satisfied that the application has met the requirements of these Regulations.

16. Approval to operate.

Upon completion of a new gas installation work, the applicant shall apply for an approval to operate it from the Director General by submitting a written application together with a Certificate of Completion issued under regulation 17 and a Test Certificate issued under regulation 18.

17. Certificate of Completion.

The Certificate of Completion referred to in regulation 16 shall be in Form B as prescribed in the First Schedule and shall be issued and signed by the appropriate competent person who supervises the installation work as specified in Table 2 of the Second Schedule.

18. Test Certificate.

(1) Before gas is supplied to a new gas installation or an additional gas installation, the new gas installation or the additional gas installation shall be tested and certified to be safe from leakage by the appropriate competent person as specified in Table 2 of the Second Schedule.

(2) Upon carrying out the test under subregulation (1), the competent person shall issue a Test Certificate which shall be in Form C as prescribed in the First Schedule.

19. Notification of an existing gas installation.

(1) No person shall commence any work on an existing gas installation without first notifying the Director General or the Gas Utility Licensee, as the case may be.

(2) The notification under subregulation (1) shall be in Form D as set out in the First Schedule.

20. Director General may order work to be suspended or stopped.

Where a person fails to comply with regulation 19, the Director General may order the work on the gas installation to be suspended or stopped.

21. Supervision of work on gas installation by competent person.

Every work on a gas installation shall be supervised by a competent person employed by the Gas Contractor who is carrying out the installation work.

22. Director General or Gas Utility Licensee to determine point of termination.

The point of termination of the gas main pipe, gas service pipe and riser in premises supplied with gas shall be determined by the Director General or the Gas Utility Licensee, as the case may be.