

Availability At Daily Maximum Demand Hour

| | | |
|---------------------|---------------|-----------|
| ST-Coal | 2,070 | MW |
| ST-Gas | 70 | MW |
| ST-Oil | 0 | MW |
| Gas | 3,615 | MW |
| Hydro | 1,857 | MW |
| Distillate | 0 | MW |
| Total TNB | 7,612 | MW |
| Total IPP | 8,585 | MW |
| Total Co-Gen | 81 | MW |
| System Total | 16,278 | MW |

Set On Bus, TNB, IPP And MD

At Daily Maximum Demand Hour : 15:00

| | | |
|------------------|---------|-----|
| TNB Generation | 7,265 | MW |
| IPP Generation | 8,372 | MW |
| Total Set On Bus | 16,177 | MW |
| Maximum Demand | 15,946 | MW |
| Spinning Reserve | 459 | MW |
| Net Energy | 324,267 | MWH |
| Load Factor | 84.7 | % |
| Total Cost | | RM |
| Cost per Unit | | RM |

Maximum Demand Record

| | | |
|--------|------------|---------------|
| Date : | 13/05/2013 | 16,562.0 MW |
| Date : | 25/06/2013 | 345,254.0 MWH |

Hourly System MW Generation

| | 0000 | 0100 | 0200 | 0300 | 0400 | 0500 | 0600 | 0700 | 0800 | 0900 | 1000 | 1100 | 1200 | 1300 | 1400 | 1500 | 1600 | 1700 | 1800 | 1900 | 2000 | 2100 | 2200 | 2300 |
|--------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| System Total | 12293 | 11547 | 11249 | 10784 | 10658 | 10592 | 10710 | 10893 | 11908 | 13842 | 14856 | 15472 | 15474 | 15221 | 15717 | 15946 | 15787 | 15136 | 14192 | 14467 | 14851 | 14514 | 14088 | 13630 |

Gas Usage

| Station | (mmscfd) |
|-----------------------|--------------|
| CBPS | 96 |
| GLGR | 64 |
| PAKA | 181 |
| PGGS | 21 |
| PGPS | 55 |
| SRDG | 76 |
| TJGS | 113 |
| TNB Total | 605 |
| KLPP | 45 |
| MPSS | 60 |
| PDPS | 61 |
| PGLA | 121 |
| PKLG | 107 |
| PTEK | 66 |
| SGB3 | 96 |
| SGRI | 198 |
| SKSP | 56 |
| YPGS | 51 |
| YPKA | 98 |
| IPP Total | 960 |
| Total Gas | 1,565 |
| Total Gas Required : | 1,565 |
| Gas Calorific Value : | 38.500 |

Generation Mix

| Type | MWh | Percentage |
|-------------------------|------------------|-----------------|
| ST-Coal | 49,577.00 | 15.29 % |
| Gas | 71,073.00 | 21.92 % |
| Hydro | 19,096.00 | 5.89 % |
| Total TNB | 139,746.0 | 43.10 % |
| ST-Coal | 64,564.0 | 19.91 % |
| ST-Gas | 10,487.0 | 3.23 % |
| Gas | 107,086.0 | 33.02 % |
| Total IPP | 182,137.0 | 56.17 % |
| Co-Gen | 2,010.0 | 0.62 % |
| Total Co-Gen | 2,010.0 | 0.62 % |
| Total Generation | 323,893.0 | 99.88 % |
| PLTG | -327.0 | -0.10 % |
| EGAT | -2.0 | 0.00 % |
| HVDC | -45.0 | -0.01 % |
| Interconnection | -374.0 | -0.12 % |
| Net Energy | 324,267.0 | 100.00 % |

Average SR During Peak Hour

| Type | MW |
|--------------|------------|
| GT | 285 |
| Hydro | 218 |
| Syncon | 196 |
| Thermal | 77 |
| Total | 776 |

| | Weather | Temperature |
|-----------|---------|-------------|
| Morning | Sunny | 27 |
| Afternoon | Hot | 35 |

| Station | Unit | 0000 | 0100 | 0200 | 0300 | 0400 | 0500 | 0600 | 0700 | 0800 | 0900 | 1000 | 1100 | 1200 | 1300 | 1400 | 1500 | 1600 | 1700 | 1800 | 1900 | 2000 | 2100 | 2200 | 2300 | | | | | | | | | | | | | | | | | | | | | | | | | | |
|---------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|-----|-----|
| PKLG | U003 | 264 | 263 | 263 | 263 | 263 | 263 | 263 | 260 | 261 | 264 | 263 | 263 | 263 | 263 | 263 | 263 | 263 | 263 | 264 | 264 | 262 | 264 | 260 | 264 | 264 | 262 | 264 | 264 | | | | | | | | | | | | | | | | | | | | | | |
| PKLG | U004 | 282 | 280 | 280 | 281 | 281 | 280 | 278 | 278 | 282 | 282 | 282 | 282 | 282 | 284 | 282 | 278 | 280 | 278 | 282 | 280 | 281 | 281 | 281 | 285 | 281 | 285 | 282 | 284 | 279 | 283 | 277 | 276 | 278 | 282 | 284 | 282 | 281 | | | | | | | | | | | | | |
| PKLG | U006 | 463 | 463 | 464 | 464 | 464 | 463 | 467 | 464 | 463 | 464 | 464 | 464 | 464 | 464 | 464 | 467 | 464 | 463 | 464 | 464 | 467 | 464 | 464 | 464 | 463 | 463 | 464 | 464 | 464 | 464 | 464 | 467 | 451 | 464 | 464 | 464 | | | | | | | | | | | | | | |
| JMIG | U001 | 684 | 688 | 686 | 685 | 684 | 686 | 686 | 686 | 684 | 686 | 688 | 684 | 686 | 688 | 687 | 685 | 683 | 686 | 684 | 688 | 683 | 687 | 683 | 685 | 687 | 684 | 684 | 686 | 688 | 682 | 686 | 684 | 686 | 688 | 683 | 686 | 687 | | | | | | | | | | | | | |
| JMIG | U002 | 689 | 690 | 690 | 691 | 690 | 686 | 691 | 689 | 692 | 688 | 689 | 689 | 692 | 690 | 689 | 688 | 689 | 692 | 693 | 691 | 702 | 688 | 689 | 691 | 692 | 692 | 689 | 689 | 691 | 688 | 689 | 689 | 691 | 688 | 692 | 691 | 688 | 692 | 691 | 689 | | | | | | | | | | |
| JMIG | U003 | 691 | 688 | 691 | 690 | 688 | 690 | 690 | 692 | 691 | 688 | 692 | 691 | 688 | 692 | 690 | 689 | 689 | 690 | 693 | 689 | 689 | 687 | 691 | 690 | 692 | 692 | 689 | 690 | 688 | 688 | 691 | 690 | 690 | 692 | 689 | 692 | 696 | 689 | 691 | 692 | 687 | 692 | 692 | 689 | 687 | | | | | |
| TBIN | U001 | 347 | 350 | 349 | 350 | 348 | 351 | 348 | 349 | 349 | 348 | 350 | 353 | 349 | 349 | 348 | 347 | 348 | 348 | 348 | 349 | 347 | 351 | 346 | 347 | 348 | 348 | 348 | 348 | 349 | 347 | 349 | 348 | 348 | 348 | 349 | 347 | 349 | 348 | 346 | 348 | 349 | 351 | 348 | | | | | | | |
| TBIN | U003 | 629 | 631 | 632 | 630 | 631 | 630 | 629 | 630 | 629 | 630 | 633 | 630 | 630 | 627 | 632 | 630 | 630 | 629 | 633 | 631 | 634 | 629 | 629 | 631 | 629 | 629 | 630 | 630 | 630 | 632 | 628 | 629 | 631 | 630 | 630 | 631 | 631 | 630 | 631 | 630 | 631 | 631 | 630 | 631 | 630 | | | | | |
| JMAH | U002 | 699 | 703 | 709 | 697 | 701 | 703 | 702 | 698 | 708 | 707 | 707 | 703 | 701 | 704 | 700 | 705 | 710 | 705 | 700 | 705 | 701 | 704 | 707 | 705 | 701 | 702 | 708 | 701 | 706 | 701 | 706 | 702 | 703 | 699 | 703 | 698 | 705 | 705 | 700 | 707 | 706 | 701 | 707 | 696 | 707 | 696 | 707 | 702 | | |
| Total ST-Coal | | 4748 | 4756 | 4764 | 4751 | 4750 | 4752 | 4754 | 4752 | 4745 | 4757 | 4766 | 4765 | 4757 | 4757 | 4751 | 4753 | 4752 | 4758 | 4763 | 4758 | 4771 | 4754 | 4754 | 4758 | 4764 | 4756 | 4751 | 4757 | 4746 | 4755 | 4754 | 4763 | 4749 | 4768 | 4751 | 4756 | 4752 | 4760 | 4761 | 4756 | 4757 | 4755 | 4747 | 4751 | 4758 | 4760 | 4762 | 4752 | | |
| PKLG | U001 | 284 | 284 | 284 | 283 | 284 | 253 | 168 | 144 | 143 | 143 | 143 | 144 | 144 | 161 | 249 | 278 | 283 | 284 | 283 | 283 | 283 | 283 | 283 | 283 | 283 | 284 | 284 | 284 | 284 | 283 | 283 | 283 | 263 | 261 | 260 | 260 | 273 | 283 | 284 | 284 | 283 | 283 | 283 | 283 | 283 | 283 | 283 | | | |
| PKLG | U002 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 15 | 45 | 69 | 91 | 147 | 218 | 281 | 284 | 285 | 283 | 283 | 282 | 282 | 282 | 282 | 282 | 282 | 281 | 281 | 277 | 281 | 281 | 282 | 283 | 282 | 282 | 282 | 282 | 282 | 282 | 282 | 282 | 282 | 282 | 282 | | |
| Total ST-Gas | | 284 | 284 | 284 | 283 | 284 | 253 | 168 | 144 | 143 | 143 | 143 | 144 | 144 | 159 | 206 | 318 | 369 | 430 | 502 | 564 | 567 | 568 | 566 | 566 | 565 | 566 | 566 | 566 | 566 | 565 | 564 | 544 | 538 | 541 | 541 | 555 | 566 | 566 | 566 | 565 | 565 | 565 | 565 | 565 | 565 | 564 | 565 | 565 | | |
| CBPS | GT1A | 98 | 99 | 99 | 99 | 99 | 98 | 99 | 99 | 89 | 88 | 89 | 88 | 88 | 93 | 99 | 98 | 99 | 99 | 99 | 98 | 99 | 99 | 99 | 100 | 99 | 100 | 99 | 99 | 100 | 99 | 99 | 98 | 99 | 100 | 99 | 99 | 98 | 99 | 99 | 99 | 99 | 99 | 99 | 99 | 99 | 99 | 99 | 99 | 99 | |
| CBPS | GT1B | 98 | 98 | 98 | 98 | 98 | 98 | 99 | 99 | 98 | 92 | 91 | 92 | 92 | 92 | 93 | 98 | 98 | 98 | 98 | 97 | 99 | 98 | 97 | 96 | 97 | 96 | 97 | 96 | 97 | 96 | 97 | 96 | 97 | 96 | 97 | 96 | 97 | 98 | 98 | 98 | 98 | 98 | 98 | 99 | 98 | 98 | 99 | 99 | | |
| CBPS | ST1C | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | 95 | | |
| GLGR | GT01 | 107 | 108 | 109 | 108 | 107 | 109 | 107 | 109 | 109 | 108 | 110 | 108 | 108 | 107 | 109 | 109 | 106 | 108 | 108 | 109 | 107 | 108 | 108 | 108 | 108 | 107 | 106 | 105 | 107 | 107 | 108 | 108 | 108 | 108 | 107 | 107 | 108 | 108 | 107 | 106 | 107 | 106 | 107 | 106 | 107 | 110 | 109 | 108 | | |
| GLGR | GT02 | 108 | 108 | 108 | 108 | 108 | 108 | 109 | 108 | 109 | 109 | 108 | 108 | 109 | 108 | 108 | 108 | 108 | 107 | 107 | 105 | 106 | 106 | 105 | 106 | 105 | 106 | 105 | 105 | 104 | 104 | 104 | 105 | 105 | 105 | 106 | 106 | 106 | 106 | 107 | 107 | 107 | 108 | 109 | 108 | 108 | 108 | 108 | 108 | | |
| GLGR | ST1C | 100 | 100 | 99 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 99 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | | |
| KLPP | GT11 | 11 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2 | 5 | 11 | 22 | 22 | 32 | 32 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | | |
| KLPP | GT12 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | | |
| KLPP | GT13 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | | |
| KLPP | GT15 | 144 | 145 | 144 | 143 | 143 | 143 | 143 | 144 | 144 | 118 | 118 | 120 | 117 | 117 | 143 | 142 | 142 | 140 | 141 | 144 | 143 | 143 | 143 | 143 | 143 | 141 | 143 | 142 | 141 | 142 | 140 | 141 | 141 | 140 | 140 | 141 | 141 | 142 | 141 | 142 | 142 | 143 | 143 | 142 | 144 | 143 | 144 | 143 | 143 | |
| KLPP | ST17 | 85 | 78 | 68 | 66 | 68 | 68 | 68 | 68 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | |
| MPSS | GT01 | 111 | 110 | 110 | 110 | 110 | 86 | 64 | 65 | 65 | 66 | 66 | 64 | 66 | 65 | 81 | 70 | 110 | 109 | 109 | 108 | 109 | 107 | 107 | 106 | 105 | 105 | 105 | 104 | 104 | 104 | 105 | 105 | 105 | 106 | 106 | 107 | 107 | 109 | 110 | 110 | 110 | 111 | 111 | 111 | 111 | 111 | 111 | 111 | 111 | 111 |
| MPSS | GT02 | 110 | 110 | 111 | 111 | 110 | 86 | 66 | 67 | 68 | 67 | 67 | 66 | 68 | 69 | 83 | 111 | 110 | 110 | 110 | 109 | 110 | 109 | 109 | 109 | 107 | 107 | 107 | 107 | 107 | 107 | 107 | 107 | 107 | 107 | 108 | 109 | 109 | 110 | 110 | 110 | 111 | 111 | 111 | 111 | 111 | 111 | 111 | 111 | 111 | |
| MPSS | ST01 | 114 | 114 | 114 | 114 | 113 | 91 | 56 | 56 | 56 | 56 | 56 | 56 | 56 | 56 | 66 | 110 | 114 | 114 | 113 | 113 | 113 | 113 | 113 | 113 | 112 | 112 | 112 | 111 | 111 | 111 | 111 | 111 | 110 | 110 | 110 | 111 | 112 | 112 | 112 | 112 | 113 | 113 | 113 | 113 | 113 | 113 | 113 | 113 | 113 | |
| PAKA | GT1A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 59 | 62 | 60 | 62 | 60 | 61 | 61 | 60 | 93 | 93 | 92 | 92 | 93 | 93 | 93 | 93 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 96 | 96 | 97 | |
| PAKA | GT1B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 60 | 60 | 60 | 59 | 60 | 60 | 60 | 59 | 60 | 93 | 93 | 93 | 93 | 93 | 93 | 93 | 93 | 94</ | | | | | | | | | | | | | |

Daily MW Generation On Monday

25-Nov-2013

| Station | Unit | 0000 | 0100 | 0200 | 0300 | 0400 | 0500 | 0600 | 0700 | 0800 | 0900 | 1000 | 1100 | 1200 | 1300 | 1400 | 1500 | 1600 | 1700 | 1800 | 1900 | 2000 | 2100 | 2200 | 2300 |
|------------------------|------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|------|
| LPIA | HY01 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 |
| MNOR | HY01 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 3 | 3 | 3 | 3 | 3 | 7 | 7 | 7 | 7 | 7 | 5 | 5 | 7 | 7 |
| PGAU | HY01 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | 129 | 108 | -1 | -1 | 81 | 128 | 80 | 80 | 83 | 130 | 112 | 82 |
| PGAU | HY02 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | 21 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 |
| PGAU | HY03 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | 132 | 20 | -1 | -1 | 29 | 114 | 132 | 132 | 112 | 116 | 113 | 114 |
| PGAU | HY04 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 82 | 82 | 35 | 80 | 88 | 130 | 129 | 129 |
| SIHY | HY01 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SIHY | HY02 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SIHY | HY03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SYPS | HY01 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SYPS | HY02 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SYPS | HY03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SYPS | HY04 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TMGR | HY01 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TMGR | HY02 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 |
| TMGR | HY03 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 |
| TMGR | HY04 | 33 | 32 | 32 | 36 | 33 | 38 | 37 | 35 | 36 | 37 | 35 | 40 | 31 | 35 | 33 | 36 | 38 | 76 | 36 | 44 | 35 | 75 | 75 | 75 |
| UPIA | HY01 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| UPIA | HY02 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Total Hydro | | 461 | 461 | 228 | 189 | 170 | 215 | 188 | 180 | 203 | 207 | 204 | 219 | 171 | 216 | 171 | 203 | 508 | 964 | 750 | 590 | 891 | 1178 | 1639 | |
| PCUF | CUFG | 44 | 46 | 45 | 45 | 46 | 47 | 45 | 46 | 47 | 48 | 47 | 45 | 46 | 47 | 46 | 45 | 43 | 43 | 42 | 42 | 42 | 42 | 43 | 41 |
| PCUF | CUFK | 40 | 40 | 41 | 40 | 39 | 39 | 40 | 41 | 39 | 39 | 38 | 40 | 39 | 42 | 40 | 39 | 41 | 41 | 39 | 39 | 41 | 36 | 39 | 40 |
| Total Co-Gen | | 84 | 86 | 86 | 85 | 85 | 86 | 85 | 87 | 87 | 88 | 84 | 85 | 84 | 87 | 86 | 88 | 85 | 82 | 84 | 83 | 83 | 81 | 82 | |
| Total Gen | | 12322 | 11944 | 11480 | 11450 | 11308 | 10946 | 10817 | 10692 | 10698 | 10646 | 10566 | 10729 | 10743 | 10909 | 11027 | 11351 | 11871 | 13180 | 13895 | 14360 | 14800 | 15043 | 15494 | |
| TIE-EGAT | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TIE-HVDC | | -29 | -29 | -29 | 30 | 31 | 29 | 30 | 30 | 30 | 31 | 30 | 30 | 31 | 30 | 30 | 31 | 30 | 30 | -196 | -195 | -198 | -198 | -196 | |
| TIE-PLTG | | 58 | 18 | -38 | -1 | 28 | -46 | 3 | -50 | 10 | 20 | -57 | -99 | 3 | 49 | 103 | 83 | -65 | 37 | 24 | -118 | -86 | -154 | -9 | |
| Interconnection | | 29 | -11 | -67 | 29 | 59 | -17 | 33 | -30 | 40 | 50 | -26 | -69 | 33 | 79 | 134 | 112 | -36 | 67 | 54 | -87 | -56 | -124 | | |
| System Total | | 12293 | 11955 | 11547 | 11421 | 11249 | 10963 | 10784 | 10722 | 10658 | 10596 | 10592 | 10798 | 10710 | 10830 | 10893 | 11239 | 11907 | 13113 | 13841 | 14447 | 14856 | 15167 | 15472 | |
| SRev ST-Coal | | 89 | 80 | 79 | 84 | 85 | 85 | 82 | 85 | 89 | 84 | 79 | 81 | 83 | 81 | 88 | 84 | 87 | 87 | 82 | 78 | 82 | 84 | 84 | |
| SRev ST-Gas | | 0 | 0 | 0 | 0 | 0 | 30 | 39 | 37 | 37 | 37 | 37 | 37 | 37 | 37 | 67 | 64 | 37 | 35 | 40 | 0 | 0 | 0 | 0 | 0 |
| SRev CCGT-Gas | | 121 | 155 | 184 | 160 | 283 | 662 | 680 | 773 | 782 | 850 | 937 | 784 | 716 | 609 | 535 | 536 | 443 | 148 | 115 | 161 | 147 | 165 | 496 | |
| SRev OCGT-Gas | | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 54 | 88 | 134 | 24 | 34 | 44 | |
| SRev Co-Gen | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Syncon | | 625 | 625 | 726 | 726 | 726 | 726 | 726 | 726 | 726 | 726 | 726 | 575 | 726 | 726 | 575 | 726 | 726 | 726 | 625 | 237 | 237 | 539 | 388 | |
| Hydro | | 127 | 127 | 159 | 98 | 117 | 72 | 99 | 107 | 84 | 80 | 234 | 68 | 116 | 222 | 116 | 84 | 80 | 161 | 376 | 232 | 429 | 375 | 199 | |
| S.Reserve Total | | 968 | 987 | 1148 | 1168 | 1311 | 1675 | 1726 | 1728 | 1718 | 1777 | 1862 | 1696 | 1678 | 1524 | 1532 | 1494 | 1272 | 722 | 938 | 1144 | 1090 | 915 | | |